

## DOCUMENT "A"

### MINISTER'S DETERMINATION CONDITIONS OF APPROVAL

Pursuant to Regulation 87-83 under the Clean Environment Act

August 11, 2010

File Number: 4561-3-1000

---

1. In accordance with section 6(6) of the Regulation, it has been determined that the undertaking may proceed following approval under all other applicable acts and regulations.
2. Commencement of this undertaking must occur within three years of the date of this determination. Should commencement not be possible within this time period, the undertaking must be re-evaluated under the *Environmental Impact Assessment Regulation* (87-83) – Clean Environment Act, unless otherwise stated by the Minister of Environment.
3. The proponent shall adhere to all obligations, commitments, monitoring and mitigation measures presented in the EIA registration document (dated March 8, 2004), as well as all those identified in all subsequent correspondence during the registration review. Additionally, the proponent shall submit a summary table detailing the status of each Condition listed in this Determination to the Manager of the Environmental Assessment Section of the Department of Environment (DENV) every six months from the date of this Determination until such a time as all the Conditions have been met.
4. If it is suspected that remains of archaeological significance are found during construction, all activity shall be stopped near the find and the Resource Manager of the Archaeological Services Unit, Heritage Branch of the Department of Wellness, Culture and Sport, shall be contacted at (506) 453-2756.
5. Well PW10 is approved for use at a maximum pumping rate of 100 USgpm for no longer than 8 hours per day (the equivalent of 182 m<sup>3</sup>/day).
6. A low-water shut-off probe must be installed in PW10 in order to prevent the lowering of the water surface in the well beyond 11 m below ground surface.
7. PW3 must be decommissioned using a method approved by the Minister of Environment. For more information, please consult the attached Guidelines for Decommissioning (Abandonment) of Water Wells.
8. A new Approval to Operate must be obtained from the Water and Wastewater Management Section (DENV). For more information, please contact the Manager of the Water and Wastewater Management Section at (506) 453-7945.
9. The municipality must formally request that the *Wellfield Protection Program/Wellfield Protected Area Designation Order* process be initiated by passing a Resolution of Council to that effect prior to bringing the new production well online. The municipality must subsequently complete a

wellfield protection study within one year of bringing the well online. The Terms of Reference for this study will be provided by DENV.