

DOCUMENT "A"

MINISTER'S DETERMINATION CONDITIONS OF APPROVAL

Pursuant to Regulation 87-83 under the Clean Environment Act

May 30, 2007

File Number: 4561-3-1101

1. In accordance with section 6(6) of the Regulation, it has been determined that the undertaking may proceed following approval under all other applicable acts and regulations.
2. Commencement of this undertaking must occur within three years of the date of this Determination. Should commencement not be possible within this time period the undertaking must be registered under the *Environmental Impact Assessment Regulation (87-83)* – Clean Environment Act again, unless otherwise stated by the Minister of Environment.
3. The proponent shall adhere to all obligations, commitments, monitoring and mitigation measures presented in the EIA registration document dated December 29, 2006 as well as all those identified in subsequent correspondence during the registration review. Additionally, the proponent shall submit a summary table detailing the status of each Condition listed in this Determination to the Director of the Project Assessment Branch of the Department of the Environment and every 6 months from the date of this Determination until such a time as all the Conditions have been met.
4. If it is suspected that the remains of archaeological significance are found during construction of the project, work shall stop immediately in the vicinity of the find, and the Archaeological Services Unit, Heritage Branch, Wellness, Culture and Sport, shall be contacted immediately at (506) 453-2756.
5. The proponent shall obtain an Approval to Construct and an Approval to Operate from the Stewardship Branch of the New Brunswick Department of Environment. The *Approval to Construct* shall be obtained prior to the commencement of any construction activities. Please contact the Manager of the Water and Wastewater Section, at (506) 444-5194 for details.
6. Refuelling and maintenance of equipment must take place in designated areas, on level terrain, a minimum of 30 m from any surface water, on a prepared impermeable surface with a collection system to contain oil, gasoline and hydraulic fluids. Appropriate spill response equipment must be maintained in a readily accessible location during project construction and operation. All spills and releases shall be promptly contained, cleaned up and reported to the 24-hour emergency response line (1-800-565-1633).